

DATE: December 6, 2019

PROJECT NAME: South Austin Regional Wastewater Treatment Plant Electrical Substation  
No. 1 Replacement Project

CIP. ID: 3333.032

IFB#: 6100 CLMC739

SUBJECT: Answers to Bidders' Questions 2 as of the date of this letter, per 00100-IFB Article 1.(3)(C).

**The following are answers to Bidders' Questions received on the above project. These answers do not modify the Contract. Any modifications to the Contract will be through Addenda**

Q-1: Will a quantity of (3) first aid kits be required per the floor plan, or merely a quantity of (2) first aid kits per the specification 16080-2.09-E?

A-1: Please refer to Addendum 2.

Q-2: Specification 4220.2.1.A.2 states that standard and split face with dense faces suitable for painting where scheduled to be painted. We are unable to find a schedule for the painting so our question is if the 12" CMU is to be painted on the interior of the substation?

A-2: No, the interior of the substation is not to be painted.

Q-3: Specification 4220.2.1.A.3 states that the color of block to be selected from the manufacturer's full range of standard integral colors. The cost of the block is more expensive if it has to be a colored block or just a standard gray block. Please advise if an integral colored block is required or if the standard grey block is acceptable.

A-3: Please provide colored block as specified.

Q-4: On sheet 782 of the plans under the concrete pavement details No. 2 requires lime stabilization under the concrete drive. This is a small area so would providing an extra 6" of base material be acceptable in lieu of doing the lime stabilization?

A-4: The requirements shall remain as shown in the bid documents.

Q-5: Would it be possible to get a painting schedule for the structural steel, joists, I beams under joists and the metal decking?

A-5: Please refer to Addendum 2.

Q-6: I am writing to request a substitution for approved equal of Raynor Worldwide insulated aluminum overhead coiling doors for the South Austin Regional WWTP Electrical Substation #1 project. Our product meets or exceeds the specification. Our local authorized Raynor dealer will provide installed pricing for the doors to the G.C.'s bidding the project if we are approved. Please find attached: Request for substitution form, Shop drawing, Brochure (see link below), Specifications.

<https://raynor.com/commercial/commercial-rolling-doors/duracoil-rolling-service-doors/>

A-6: Specification 08330 is not proprietary. Any acceptable product must meet the specification requirements.

**END**